

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1   3</div>	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0004</div>		3. EFFECTIVE DATE <div style="text-align: center;">09-Jul-2004</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">W16ROE-4097-7584</div>		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, NEW YORK ATTN: CENAN-CT ROOM 1843 26 FEDERAL PLAZA NEW YORK NY 10278		CODE <div style="text-align: center;">W912DS</div>		7. ADMINISTERED BY (If other than item 6) CONSTRUCTION DIVISION 26 FEDERAL PLAZA ROOM 2137 NEW YORK NY 10278		CODE <div style="text-align: center;">E3M1000</div>	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. W912DS-04-B-0009	
				X		9B. DATED (SEE ITEM 11) 27-May-2004	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment 0004 to solicitation W912DS-04-B-0009 is to respond to questions asked by potential bidders in the attached Question and Answer format. As a result of this amendment, the due date for receipt of bids, Bid Opening Date (BOD), is changed as follows:  FROM: 13 JULY 2004 @ 1:30 P. M. TO: 15 JULY 2004 @ 1:30 P. M.  NOTE: Bidders must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation, or as amended, by one of the following methods: In the space provided on the SF 1442, by separate letter, by telegram, or by signing block 15 below. FAILURE TO ACKNOWLEDGE AMENDMENTS BY THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR BID IN ACCORDANCE WITH THE LATE BID, LATE MODIFICATIONS OF BIDS, OR LATE WITHDRAWAL OF BIDS (FAR 14.304) RULE. All other terms and conditions remain unchanged, and in full force and effect.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  09-Jul-2004	

EXCEPTION TO SF 30  
APPROVED BY OIRM 11-84

30-105-04

STANDARD FORM 30 (Rev. 10-83)  
Prescribed by GSA  
FAR (48 CFR) 53.243

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## SUMMARY OF CHANGES

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0004 CHANGESNOTICE TO BIDDERS

Failure of the bidder to  
Acknowledge receipt of  
this Amendment in  
Item 19 of Standard Form  
1442 (Pg. 00010-2) may  
result in REJECTION of  
the bid.

IFB NO. W912DS-04-B-0009

Amendment No. 4

Department of the Army, NYD  
Corps of Engineers  
New York, NY 10278-0090

**AMENDMENT NO. 4: CLARIFICATION TO SPECIFICATIONS FOR GREEN BROOK SUB BASIN OF THE  
RARITAN RIVER GREEN BROOK FLOOD CONTROL PROJECT, RINGWALL AROUND  
APARTMENT COMPLEX AT 500 EAST UNION AVENUE**

TO BIDDERS

1. **Bid Opening:** The date for Bid Opening is changed to 1:30 PM Thursday 15 July 2004. The place for Bid Opening remains unchanged.
2. **Specifications:**

These questions and answers are for informational purposes only

COMMENT: Please tell us where the location of the utility pole is from which we will be running the underground service feeders. Otherwise, please give us a footage from the pole to the service panel.

**RESPONSE: In accordance with the Plans, there is an approximate distance of 325 feet between the utility service pole and the local utility company metering panel shown on Sheet 26, Lighting Plan. The electric service should be provided by the local utility company to the utility pole located approximately 70 feet west of the driveway entrance along East Union Avenue.**

COMMENT: Please give a wall detail so we can determine the embedded box requirements for the lighting fixtures on the wall.

**RESPONSE: All electric boxes shall be rated NEMA 4X and designed for embedment in concrete. All boxes to be in place prior to the concrete pour for the cast-in-place wall.**

COMMENT: Our assumption is that someone else will be providing the pump control panel to the electrician. Is that correct?

**RESPONSE: The intent of the design is to have the pump vendor provide the control panel.**

COMMENT: We do not see any specific fixture type requirements, or panel type requirements. Will these choices be left up to the electrician?

**RESPONSE: The types of fixtures are identified on the contract documents.**

3. This Amendment shall be attached to the specifications and shall be a part thereof.

SECTION 00010 - SOLICITATION CONTRACT FORM

The required response date/time has changed from 13-Jul-2004 01:30 PM to 15-Jul-2004 01:30 PM.

(End of Summary of Changes)